



DATE: July 2, 2024

PROJECT: 69 kV Transmission Line Reconstruction
City of Webster City/Municipal Utilities
Webster City, Iowa
DGR Project No. 428404

LETTING: July 23, 2024; 2:00 P.M
City Hall
400 Second Street
Webster City, IA 50595


ADDENDUM NO. 1

This ADDENDUM NO. 1 hereby revises the Contract Documents dated June 18, 2024. Revisions made herein shall become a binding part of the Contract Documents.

- 1. Engineered Laminated Wood Pole Details:** Estimated dimensions and weights of the Owner-Furnished laminated wood poles are shown in the drawing 'Engineered Laminated Wood Pole Details' attached to this Addendum. These dimensions and weights are subject to change.

This ADDENDUM NO. 1 shall become a legal and binding part of the Contract Documents. All BIDDERS shall acknowledge receipt of this ADDENDUM NO. 1 on the BID FORMS and agree to accept the revisions indicated and prepare proposals in accordance therewith.

DGR Engineering

By 
Dennis J. Haselhoff, P.E.
Iowa License No. 13674

Engineered Laminated Wood Poles

Structure #	Minimum Structure Length	Above-Ground Length	Minimum Setting Depth	Estimated Structure Weight (lbs)	Minimum Foundation Diameter
1	71'-0"	60'-0"	11'-0"	9,000	4'-6"
2	71'-0"	60'-0"	11'-0"	14,000	5'-6"
3	74'-6"	63'-0"	11'-6"	13,000	5'-6"
5	76'-6"	65'-0"	11'-6"	9,000	4'-6"
6	76'-6"	65'-0"	11'-6"	9,000	4'-0"
7	82'-0"	70'-0"	12'-0"	6,500	4'-0"
8	90'-0"	77'-0"	13'-0"	8,000	4'-0"
17	66'-0"	55'-0"	11'-0"	13,000	6'-0"
27	88'-0"	75'-0"	13'-0"	16,000	6'-0"
29	99'-0"	85'-0"	14'-0"	17,000	6'-0"
31	66'-0"	55'-0"	11'-0"	5,000	3'-6"
32	71'-0"	60'-0"	11'-0"	4,500	3'-6"
33	76'-6"	65'-0"	11'-6"	5,000	3'-6"
34	71'-0"	60'-0"	11'-0"	19,000	6'-0"
35	73'-0"	62'-0"	11'-0"	13,000	5'-6"
37	66'-0"	55'-0"	11'-0"	25,000	6'-0"
38	66'-0"	55'-0"	11'-0"	30,000	6'-0"
43	66'-0"	55'-0"	11'-0"	8,000	5'-6"
44	66'-0"	55'-0"	11'-0"	8,000	5'-6"
47	71'-0"	60'-0"	11'-0"	18,000	5'-6"
1	71'-0"	60'-0"	11'-0"	18,000	5'-6"
2	71'-0"	60'-0"	11'-0"	20,000	6'-0"
5	71'-0"	60'-0"	11'-0"	20,000	6'-0"
7	71'-0"	60'-0"	11'-0"	20,000	6'-0"
12	75'-6"	64'-0"	11'-6"	19,000	5'-0"
15	66'-0"	55'-0"	11'-0"	4,000	3'-0"
16	69'-0"	58'-0"	11'-0"	16,000	5'-6"
17	71'-0"	60'-0"	11'-0"	16,000	5'-6"
23	73'-6"	62'-0"	11'-6"	20,000	5'-6"

*All dimensions and weights shown are estimated and are subject to change.
THIS DRAWING IS PROVIDED FOR INFORMATIONAL PURPOSES ONLY.

REV	DATE	DESCRIPTION
A	07-02-2024	ISSUED FOR BIDS



Project Manager: DJH
 Designer: DYS
 Project Number: 428404
 Phone: (712) 472-2531

WEBSTER CITY MUNICIPAL UTILITIES
 WEBSTER CITY, IOWA

ENGINEERED LAMINATED WOOD POLE DETAILS
 69 kV TRANSMISSION LINE RECONSTRUCTION